

|                                                              |                                                  |                                                                                     |                   |
|--------------------------------------------------------------|--------------------------------------------------|-------------------------------------------------------------------------------------|-------------------|
| Project Number:<br><b>20011</b>                              | Document Type:<br><b>Quick Reference</b>         |  |                   |
| Date:<br><b>16-Apr-2021</b>                                  | Product Name:<br><b>Service FW-Update Packet</b> | Revision:<br><b>A</b>                                                               |                   |
| <b>HISTORY</b>                                               |                                                  |                                                                                     |                   |
| Rev                                                          | Date                                             | Comment                                                                             | Author            |
| A                                                            | 16-Apr-2021                                      | Initial                                                                             | Thomas Wiedebusch |
|                                                              |                                                  |                                                                                     |                   |
|                                                              |                                                  |                                                                                     |                   |
|                                                              |                                                  |                                                                                     |                   |
|                                                              |                                                  |                                                                                     |                   |
|                                                              |                                                  |                                                                                     |                   |
|                                                              |                                                  |                                                                                     |                   |
|                                                              |                                                  |                                                                                     |                   |
|                                                              |                                                  |                                                                                     |                   |
|                                                              |                                                  |                                                                                     |                   |
|                                                              |                                                  | Copyright © 2021 by<br>SENSUS GmbH                                                  |                   |
|                                                              |                                                  |                                                                                     |                   |
|                                                              |                                                  |                                                                                     | Confidential      |
| File: Quick Reference Cordone! Service FW-Update Packet.docx |                                                  |                                                                                     |                   |

REVIEWS

| Rev | Date | Reviewer | Department |
|-----|------|----------|------------|
|     |      |          |            |
|     |      |          |            |
|     |      |          |            |
|     |      |          |            |
|     |      |          |            |
|     |      |          |            |
|     |      |          |            |
|     |      |          |            |
|     |      |          |            |
|     |      |          |            |

## LIST OF CONTENTS

|     |                                            |    |
|-----|--------------------------------------------|----|
| 1.  | Introduction.....                          | 5  |
| 1.1 | Content.....                               | 5  |
| 2.  | Security Concept.....                      | 5  |
| 2.1 | FW-Update Process.....                     | 5  |
| 2.2 | FW-Update Builder .....                    | 5  |
| 2.3 | FW-Update Safe.....                        | 5  |
| 2.4 | FW-Update Loader.....                      | 6  |
| 2.5 | FW-Update Software.....                    | 6  |
| 3.  | FW-Update Process Security .....           | 6  |
| 3.1 | Early-Check - FW-Update Builder.....       | 6  |
| 3.2 | Late-Check - FW-Update Software .....      | 7  |
| 3.3 | Final-Check – Cordone! Bootloader FW ..... | 7  |
| 4.  | System Overview .....                      | 8  |
| 4.1 | Software Products .....                    | 10 |
| 4.2 | Data Containers.....                       | 13 |
| 5.  | Contact Information .....                  | 16 |
| 6.  | References .....                           | 16 |

## LIST OF TABLES

|           |                    |    |
|-----------|--------------------|----|
| Table 1.1 | Abbreviations..... | 4  |
| Table 4.1 | Contacts.....      | 16 |

## LIST OF FIGURES

|            |                                |    |
|------------|--------------------------------|----|
| Figure 3.1 | System Connections .....       | 8  |
| Figure 3.2 | System Overview .....          | 9  |
| Figure 3.3 | FW-Update Builder .....        | 10 |
| Figure 3.4 | FW-Update Loader.....          | 11 |
| Figure 3.5 | FW-Update Software.....        | 12 |
| Figure 3.6 | FW-Update Safe.....            | 14 |
| Figure 3.7 | FW-Update Report- Example..... | 15 |

### ABBREVIATIONS

|                               |                                                                                                           |
|-------------------------------|-----------------------------------------------------------------------------------------------------------|
| Builder Operator              | Operator of the “FW-Update Builder” assembling the “FW-Update Safe”                                       |
| Cordonel™                     | Ultra Sonic Water Meter                                                                                   |
| Cordonel<br>Service FW-Update | Project name for entire product                                                                           |
| DLL                           | Dynamic Link Library                                                                                      |
| FW                            | Firmware, hardware depending software, here the collection of all applications                            |
| FW-Update Builder             | Builder of the “FW-Update Safe”, tool to select all needed components and to encrypt the “FW-Update Safe” |
| FW-Update Loader              | Software for decryption of the “FW-Update Safe” and loader for the “FW-Update Software”                   |
| FW-Update Process             | The process of installing the firmware in the Cordonel                                                    |
| FW-Update Safe                | Encrypted container of all components needed for the “FW-Update Process” during offline operation         |
| FW-Update SW                  | Software executing the “FW-Update Process”                                                                |
| Genesis                       | Legacy Name of Cordonel                                                                                   |
| HW                            | Hardware                                                                                                  |
| Offline Operation             | Without connection to the Xylem-Network                                                                   |
| Online Operation              | Directly or via VPN connected to the Xylem-Network                                                        |
| SW                            | Software                                                                                                  |
| Update Opertor                | Operator executing the “FW-Update Process”                                                                |
| VPN                           | Virtuel Private Network,                                                                                  |

*Table 1.1 Abbreviations*

## 1. Introduction

The “Cordonel Service FW-Update” shall facilitate an update of the Cordonels™ in the field. As this may be somewhere in the desert without any internet connectivity, the process has to be executed in offline-operation.

### 1.1 Content

The “Quick Reference Cordonel FW-Update Packet” gives an introduction to the project. It covers all common and general items.

## 2. Security Concept

For the “FW-Update Process” the Cordonel has to be unsealed. Therefore the administrator level password is needed. As this has to be delivered to the update operator, security concerns have to be taken into account.

### 2.1 FW-Update Process

The “FW-Update Process” is permitted exclusively for Xylem/Sensus employees.

### 2.2 FW-Update Builder

The “FW-Update Builder” is secured by:

- Online Operation is essential for the functionality,
- Program validation of a specific version taken from the data base, can be deactivated in the data base, program will exit immediately if validation expired,
- Validation refresh on day change,
- Builder Operator licensing, account will be controlled by the data base, the “FW-Update Builder” user interface is locked for disabled accounts,
- The production data base access is protected by Web-Interfaces.

### 2.3 FW-Update Safe

The “FW-Update Safe” is a container for all data needed for the update process. As these data are potentially a high risk to the Cordonel access restrictions, these are secured by:

- The “FW-Update Safe” is encrypted with a AES-CGM algorithm and an AES256-Key,
- The safe does only contain the access codes for a selected subset of Cordonels,
- Every safe is strongly linked to a specific update operator,
- Each safe is usable exclusively on a dedicated hardware (Update Operator PC),
- The “FW-Update Safe” is additionally encrypted with a 256 bit random code, this safe cannot be used after new registration (not even an administrator can open this safe anymore),
- The “FW-Update Safe” has a validation date, beyond this date the “FW-Update SW” will become inoperable,

- If the update operator license expires, the builder operator cannot assign new “FW-Update Safes” to this user.

## 2.4 FW-Update Loader

The “FW-Update Loader” program is not secured by any license information. This is not needed due to these conditions:

- Each Update Operator has to be registered to be able to decrypt the “FW-Update Safes”,
- As all “FW-Update Safes” are personalized, these can be exclusively decrypted by a specific user,
- One update operator can be registered per user profile on one hardware, multiple users can use the identical hardware but are unable to decode the “FW-Update Safes” of a colleague,
- Changing the hardware will require a new registration, which will automatically invalidate all previously generated “FW-Update Safes”,
- A registration is going to outdate after 21 days. If the update operator is still active, he can refresh this time as often as required,
- Each profile is secured by the Xylem-Password-Policy, every update operator has to be logged in to access his personal folders (Download – for the FW-Update Safes, App Roaming – for specific user settings).

## 2.5 FW-Update Software

The “FW-Update SW” is secured by:

- Program validation of a specific version and due date contained as license in the “FW-Update Safe”, program will exit immediately if the license expired,
- The “FW-Update SW” program is part of the “FW-Update Safe”, always the latest version is available to the update operator,
- The “FW-Update SW” is delivered in an not executable format. The loader is needed to start this software,
- The security relevant data like passwords, license information and “FW-Update Packages” will be directly passed from the “FW-Update Loader” to the “FW-Update Software”. It will never be saved intermediately to the hard disk to avoid copy or modifications.

## 3. FW-Update Process Security

The process security has to assure that only validated FW is going to be installed on a specific CordoneL. Furthermore, the “FW-Update Process” has to be fail safe to keep the CordoneL operable, even if the update could not be finalized.

### 3.1 Early-Check - FW-Update Builder

- Collect data of CordoneL and FW-Packages and perform an Update-Capability-Check
- FW-Update Safe contains exclusively approved FW versions.

### 3.2 Late-Check - FW-Update Software

---

- Compare FW-Package information with installed FW-Version and perform an Update-Capability-Check for the core version and installed metrology,
- Monitor download status of applications,
- Execute “burn” command after successful download.

### 3.3 Final-Check – Cordone! Bootloader FW

---

- Cordone! takes exclusively applications with a secured format,
- Update installation will be executed if all required applications are validated,
- If update will be denied, the Pre-Update-FW will be kept as is, keeping the Cordone! fully functional.

#### 4. System Overview

The system has two operational modes:

- The online operation, used to collect the data, generate the “FW-Update Safe”, download the “FW-Update Safes” and upload the reports.
- The offline operation which performs the “FW-Update Process”.




Figure 4.1 System Connections

The System consists of three software products, the “FW-Update Builder”, the “FW-Update Loader” and the “FW-Update SW”. Two data containers will be exchanged between the offline and online operation, the encrypted “FW-Update Safe” and the “FW-Update Reports”.




Figure 4.2 System Overview

## 4.1 Software Products

The “FW-Update Builder” referenced in [FWU\_BLD].





Figure 4.3 FW-Update Builder

The “FW-Update Loader” referenced in [FWU\_LDR].



*Figure 4.4 FW-Update Loader*

The “FW-Update SW” referenced in [FWU\_SW].





Figure 4.5 FW-Update Software

## 4.2 Data Containers

The “FW-Update Safe” is the central data exchange container between the “FW-Update Builder” and the “FW-Update Loader”. It contains:



### Legend:

- \*Examples
- Padlock for Encrypted Container

*Figure 4.6 FW-Update Safe*

The “FW-Update Report” files are the application list and a readable text file with the update process information. The following listing will show one example (extraction of a few lines before and the after the update):

```
-----
Date: 15/04/2021
FW-Update SW: 1.0.7775
Customer Name: Sensus GmbH Hannover
Order Number: 999991066-99
-----

PCB ID: 182100041
System Core Revision:1.64
Installed applications:
Appld: 0x00 - V: 4.90 - CRC: 0x223B - AppName: SYSTEM
Appld: 0x01 - V: 0.67 - CRC: 0x9ACE - AppName: POWERMON
Appld: 0x04 - V: 2.19 - CRC: 0xF967 - AppName: CONFIGEXCHANGE
Appld: 0x05 - Not installed - AppName: OPTICALPORT
Appld: 0x08 - V: 0.17 - CRC: 0xDC48 - AppName: LOGGER
Appld: 0x09 - V: 1.51 - CRC: 0x0DF9 - AppName: CUSTOMER
Appld: 0x0A - Not installed - AppName: FUNCTEST
Appld: 0x0F - V: 2.95 - CRC: 0xAE5A - AppName: GENESISFLOW
Appld: 0x10 - V: 4.53 - CRC: 0xCC1C - AppName: SENSUSRADIO
Appld: 0x11 - V: 0.69 - CRC: 0xE2F9 - AppName: PERIODICLOG
Appld: 0x12 - V: 1.06 - CRC: 0x20F6 - AppName: METROLOGYASST
Appld: 0x14 - V: 1.97 - CRC: 0x4B73 - AppName: IRDA
Appld: 0x15 - V: 0.53 - CRC: 0xB3D8 - AppName: NFC
Appld: 0x16 - Not installed - AppName: NA2WLOGGER
Appld: 0x17 - Not installed - AppName: NA2WALARMS
Appld: 0x18 - V: 10.6D - CRC: 0x1C8D - AppName: FLEXNETVERSION
Appld: 0x1A - Not installed - AppName: FLEXNETSERIAL
Appld: 0x62 - Not installed - AppName: TESTMANAGER
-----

FW Update: PROD_EMEA_433_DN50_R106B
Update information complete.
Core version is compatible.
Metrology version is approved
Update capability validated.
Reading configuration.....
Reading registers before update
Read register: CONFIGEXCHANGE_ConfigAccessRights - 00-00-01-80 – 384

....

Cordonel authentication succeeded.
-----

Date: 15/04/2021
FW-Update SW: 1.0.7775
Customer Name: Sensus GmbH Hannover
Order Number: 999991066-99
-----

PCB ID: 182100041
System Core Revision:1.64
Installed applications:
Appld: 0x00 - V: 4.92 - CRC: 0xE038 - AppName: SYSTEM
Appld: 0x01 - V: 0.67 - CRC: 0x9ACE - AppName: POWERMON
Appld: 0x04 - V: 2.19 - CRC: 0xF967 - AppName: CONFIGEXCHANGE
Appld: 0x05 - Not installed - AppName: OPTICALPORT
Appld: 0x08 - V: 0.17 - CRC: 0xDC48 - AppName: LOGGER
```

Appld: 0x09 - V: 1.51 - CRC: 0x0DF9 - AppName: CUSTOMER  
Appld: 0x0A - Not installed - AppName: FUNCTEST  
Appld: 0x0F - V: 2.95 - CRC: 0xAE5A - AppName: GENESISFLOW  
Appld: 0x10 - V: 4.55 - CRC: 0xE64D - AppName: SENSUSRADIO  
Appld: 0x11 - V: 0.69 - CRC: 0xE2F9 - AppName: PERIODICLOG  
Appld: 0x12 - V: 1.06 - CRC: 0x20F6 - AppName: METROLOGYASST  
Appld: 0x14 - V: 1.97 - CRC: 0x4B73 - AppName: IRDA  
Appld: 0x15 - V: 0.53 - CRC: 0xB3D8 - AppName: NFC  
Appld: 0x16 - Not installed - AppName: NA2WLOGGER  
Appld: 0x17 - Not installed - AppName: NA2WALARMS  
Appld: 0x18 - V: 10.6B - CRC: 0xC515 - AppName: FLEXNETVERSION  
Appld: 0x1A - Not installed - AppName: FLEXNETSERIAL  
Appld: 0x62 - Not installed - AppName: TESTMANAGER

-----

....

Read register: SYSTEM\_UpgradePermissions - 00-00-00-00 - 0  
Configuration readout succeeded.  
File access active....

-----

Files read from meter:  
0\config  
0\password  
1\evtdata  
1\logindex  
1\fdrrdata  
1\logdata

-----

File readout succeeded.  
File access active....

-----

Files restored to meter:  
1\tstfile

-----

File restore succeeded.  
File access active....

-----

Files read from meter:  
0\config  
0\password  
1\evtdata  
1\tstfile  
1\logindex  
1\fdrrdata  
1\logdata

-----

File readout succeeded.  
Password file restore succeeded.  
Firmware update succeeded.

-----

Firmware is up to date!

-----

*Figure 4.7 FW-Update Report- Example*

**5. Contact Information**

| Name | Function | Mail |
|------|----------|------|
|      |          |      |
|      |          |      |
|      |          |      |
|      |          |      |
|      |          |      |

*Table 5.1 Contacts***6. References**

- [FWU\_MRD]      **Cordonel Service FW-Update Process MRD; Published: SENSUS GmbH;**  
Author: Thomas Wiedebusch; Edition: September 2020 - Revision B
- [FWU\_BLD]      **Quick Reference Cordonel Service FW-Update Builder; Published: SENSUS GmbH;**  
Author: Thomas Wiedebusch; Edition: April 2021 - Revision A
- [FWU\_LDR]      **Quick Reference Cordonel Service FW-Update Loader; Published: SENSUS GmbH;**  
Author: Thomas Wiedebusch; Edition: April 2021 - Revision A
- [FWU\_SW]      **Quick Reference Cordonel Service FW-Update Software; Published: SENSUS GmbH;**  
Author: Thomas Wiedebusch; Edition: April 2021 - Revision A